

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO. 2545-0270:100 Page 1 of 1

CATEGORY: Operable Partitions

LISTEE: Modernfold, 1711 "I" Avenue, New Castle IN 47362
Contact: Tom Goldsmith *(563) 875-7136

DESIGN: Models 800 and 1200 accorian folding partitions. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	FINISH	FLAME	SMOKE
	TYPE	SPREAD	DEVELOPED
	Barrister 30 oz (water)	10	30
	Barrister 30 oz (solvent)	15	40
	Woodgrain 30 oz	5	20
	Tufted Loop 15 oz	15	25
	Embossed Vinyl 30 oz	15	45
	Foamed Back Fabric	20	40

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and CSFM label.

APPROVAL: Listed as a folding partition where Class I flame spread is required. Authority having jurisdiction should be consulted prior to installation.

NOTE: Only the flame spread of the finishes were examined.

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager